



solarcombi+

WP4 – Task1 : Standard configurations' analysis

Solar Combi+ Project meeting
Gleisdorf 17th - 18th December 2009

Identification of most promising markets and promotion of standardised system configurations for the market entry of small scale combined solar heating & cooling applications
EIE/07/158/SI2.466793 09/2007 – 02/2010

Intelligent Energy  Europe

The sole responsibility for the content of this publication lies within the authors. It does not necessarily reflect the opinion of the European Communities. The European Commission is not responsible for any use that may be made of the information contained therein.



Task 1 – Standard system configurations

Project proposal states:

Objective

Standard system configurations, independent of specific product, to be communicated and promoted towards a **wide audience**

Task

Definition of a reduced number of "standard system configurations" which can be promoted and applied **similarly to the standard systems for DHW** with **reasonably good results in typical/average cases** (mostly technology independent)

Outcome

Standard system configurations (3 to 5), which are independent of specific product and work best under different circumstances



Standard System Configuration

	WCT				HC				DC			
	ET		FP		ET		FP		ET		FP	
	CC	A	X	A	X	A	X	A	X	A		A
B		X	B	X	B	X	B	X	B		B	
C		X	C	X	C	X	C	X	C	X	C	X
D		X	D	X	D	X	D	X	D		D	
E			E	X	E		E	X	E		E	
FC	ET		FP		ET		FP		ET		FP	
	A	X	A	X	A	X	A	X	A		A	
	B	X	B	X	B	X	B	X	B		B	
	C	X	C	X	C	X	C	X	C	X	C	X
	D		D		D		D		D		D	
E		E	X	E		E	X	E		E		



Task 1 – Standard system configurations


- total solar fraction
- total electrical efficiency
- yearly relative primary energy saved

Suitable solutions = {solutions | $SF_{tot} > 60\%$, $COP_{el} > 10$, $PES_{rel} > 0$ }

Suitable solutions = {solutions | $SF_{tot} > 40\%$, $COP_{el} > 15$, $PES_{rel} > 0$ }



Standard System Configuration





Standard System Configuration

	NAPLES		OFFICE		ROTARTICA	
	WC		DC		HC	
	ET	FP	ET	FP	ET	FP
FC	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$
CC	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$	$_{-} \text{m}^2/\text{kW}$ $_{-} \text{l}/\text{m}^2$



Task 1 – Standard system configurations

		WCT				HC				DC				
		ET		FP		ET		FP		ET		FP		
		5.0	m ² /kW	5.0	m ² /kW	5.0	m ² /kW	5.0	m ² /kW	5.0	m ² /kW	5.0	m ² /kW	
Total Solar Fraction [%]		75.0		l/m ²		75.0		l/m ²		75.0		l/m ²		
		CC	A	86.1	A	81.4	A	86.2	A	81.4	A	0.0	A	0.0
			B	73.3	B	67.1	B	0.0	B	73.1	B	0.0	B	0.0
			C	87.0	C	83.0	C	82.5	C	77.1	C	80.2	C	74.2
			D	82.5	D	77.8	D	81.5	D	76.6	D	0.0	D	0.0
			E	0.0	E	90.3	E	0.0	E	0.0	E	0.0	E	0.0
		FC	ET		FP		ET		FP		ET		FP	
5.0	m ² /kW		5.0	m ² /kW	5.0	m ² /kW	5.0	m ² /kW	5.0	m ² /kW	5.0	m ² /kW		
75.0			l/m ²		75.0		l/m ²		75.0		l/m ²			
A	87.1		A	81.8	A	86.4	A	81.0	A	0.0	A	0.0		
B	0.0		B	0.0	B	0.0	B	0.0	B	0.0	B	0.0		
C	0.0		C	0.0	C	0.0	C	0.0	C	0.0	C	0.0		
D	0.0		D	0.0	D	0.0	D	0.0	D	0.0	D	0.0		
E	0.0	E	89.1	E	0.0	E	0.0	E	0.0	E	0.0			



Task 1 – Standard system configurations

BEST Configurations:

All the best configurations are related to the largest collectors' area (**5 m²/kW_{ref}**) and storage volume (**75 l/m²**) simulated: in fact, even though smaller areas allow to cover rated heat fluxes at the generator of the sorption chillers to cover most of the cooling load at summer time, in winters, larger areas are required if heating and DHW preparation are needed, due to the significantly reduced radiation available.

The residential applications in Naples feature values of total solar fraction that vary between **67% and 87%** for the low consumption building (R60) and **60% - 78%** for the average consumption building (R100). Toulouse applications range between **46% and 55%** in the case of low consumption building and between **40% and 46%** for the average consumption building



Task 1 – Standard system configurations

Primary energy saved in Naples varies between **30%-70%** and **25%-60%** for the R60 and the R100 building. In Toulouse, values vary between **23%-45%** and **25%-40%** for the R60 and the R100 building respectively.

- **Higher regimes for the Heat rejection and high night loads in Naples.**

Between **12 and 24** for the low consumption building (R60), **12 and 30** for the average consumption building (R100) in Naples, between **24 and 50** for the R60 building and **30 and 70** for the R100 in Toulouse

- **Lowest values with fan coils: lower limit reached in many cases.**
- **Highest values whit SonnenKlima ...**



Task 1 – Standard system configurations

In office applications, mostly SonnenKlima “survives” to COP check.

For chiller “A” in office applications, the relative PES ranges between **63% and 78%** in Naples, **55% and 71%** in Toulouse and **26% and 40%** in Strasbourg. The total solar fraction approaches the **unity** in Naples, varies between **80% and 90%** in Toulouse and ranges between **50% and 60%** in Strasbourg.


Only one case with chiller “E” (Solution/EAW) “survives” in Strasbourg.

Task 1 – Standard system configurations

STANDARD Configurations:


The **three best configurations** for each set of parameters were selected as **standard configurations** and a sensitivity analysis was carried out on the basis of:

- total solar fraction
- cooling solar fraction
- relative primary energy saved
- total electrical efficiency
- gross solar yield




Task 1 – Standard system configurations

Collectors comparison



Building comparison




In Naples the evacuated tubes allow increasing the performance of 5 to 7%, while in Toulouse the gain is higher, but still limited to around 10%


The impact of the building efficiency is a reduction of 7 to 10% when going from R60 to R100

Task 1 – Standard system configurations

Collectors comparison - Naples




Collectors comparison - Toulouse




The values are higher than the corresponding total solar fraction ones: in Naples they are in the range 70%-95%, whereas in Toulouse they vary from 50% to 95%. A large variability of values is detected in Toulouse: being lower the radiation levels, only machines working at lower temperatures can reach nominal operating conditions for large periods of time.

Task 1 – Standard system configurations

Collectors comparison - Naples



Collectors comparison - Toulouse




The effect of reducing the storage volume from 75 l/m² to 50 l/m² is a quite significant reduction of about 9-10%. The outcome of additionally reducing the collectors area is a drop of the values calculated of around 12-17%.

Relative primary energy saved varies of about 10% in Naples and 5% in Toulouse, depending on the collectors technology used: variations in a range of 15-30%.




Task 1 – Standard system configurations

Distribution system - Naples




Distribution system- Toulouse




Fan coils utilization requires a higher heat rejection, producing larger electrical energy consumption; the effect is still very limited in Toulouse, while it might result in a quite large reduction of the system performance (5-10%) in Naples.

Task 1 – Standard system configurations

Collectors comparison - Naples




Collectors comparison - Toulouse




The latter analysis holds also regarding the total electrical efficiency: higher summer electrical energy consumption brings to much lower data in Naples (i.e. range 10-25%) than in Toulouse (range 25-40%).

Task 1 – Standard system configurations

Collectors comparison - Naples




Collectors comparison - Toulouse




A strong dependence on the collectors area is evident: smaller areas work better since the ratio between the energy gathered and the loads is lower; the energy is therefore better used in the system and the return temperature to the collectors is lower. This produces lower thermal losses toward the environment. For the same reason much lower stagnation is encountered.

Task 1 – Standard system configurations

Total solar fraction




Cooling solar fraction




Office buildings

Task 1 – Standard system configurations

Relative PES - Naples



Relative PES - Strasbourg




Office buildings




Task 1 – Standard system configurations

EI COP - Naples



EI COP- Strasbourg




Office buildings




Task 1 – Standard system configurations

GSY - Naples



GSY - Strasbourg



Office buildings



Task 1 – Standard system configurations

Cooling solar fraction decreases if the backup heater is not used. This is due to the fact that the heater allows higher temperatures at chillers inlet (and also at the outlet); therefore, also higher temperatures at the collectors are temporarily produced and thus higher solar fractions. In Naples the decrease is around 3%-5%, while higher values are encountered in Toulouse, i.e. around 5%-10%.

The largest effects are however encountered if yearly relative primary energy is considered. The saving of fossil fuel increases this figure in a range of 10%-30% (absolute). For the same reasons reported above, the best effects are encountered in Naples where 20%-30% higher savings are obtained, while in Toulouse more moderate increases are achieved around 10%.